

# Certificate of Conformity

By the product certificate number:

No. 250041RECO01-C-CER

Issued to:

License holder: **Victron Energy B.V.**  
De Paal 35, 1351JG, Almere, Netherlands

Trademark:



Contract number: 802190

It is certified that the product:

Type of product: **Inverter/Charger with UPS functionality**

Product Family: **Multiplus II - 3phase configuration**

Models:	MultiPlus-II 48/8000/110-100 230V	MultiPlus-II 48/10000/140-100 230V	MultiPlus-II 48/15000/200-100 230V
Rated characteristics:			
Rated Power	8 kVA / 6.4 kW	10 kVA / 8 kW	15.0 kVA / 12.0 kW
Rated Voltage		AC input: 187-250 V <sub>ac</sub> DC input: 38-66 V <sub>dc</sub> AC output: 220-240 V <sub>ac</sub> DC output: 48 V <sub>dc</sub>	
Rated Frequency		50 Hz	
Firmware version	2621552	2627552	2619552
Number of phases		Three Phase <sup>(1)</sup> (3L/N/PE)	
Isolation transformer		Yes	

(1) The three-phase system consists of three individual inverters (of the same model) placed in parallel.  
(1) See on page 2 installation scheme.

Is in compliance with the standard:

- **Technical Prescription C10/11 of Synergrid. Edition 2.2 (15.03.2021) <sup>(?)</sup>**

<sup>(?)</sup> Equipment considered to be connected to power generating plants of Type A (< 1 MW) to the low voltage grid (≤1kV)

This certificate is based upon test results offered in the test report No. 2222/0478-C issued on 05<sup>th</sup> July 2023.

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-35 based on the requirements of the UNE-EN ISO/IEC 17065.

This certificate is first issued on 21<sup>st</sup> February 2025.

This certificate is valid until the 21<sup>st</sup> February 2030.

Madrid, 21<sup>st</sup> February 2025

Daniel Arranz Muñiz  
Certification Manager



SGS Tecnos, S.A.U. C/ Trespaderne, 29 - 28042 Madrid  
This certificate is issued by SGS under its General Conditions for Product Certification at [www.sgs.com/terms\\_and\\_conditions](http://www.sgs.com/terms_and_conditions).  
The status and validity of the certificate can be checked scanning the QR code above included or through the following web [link](#).  
This document cannot be reproduced partially



No. 250041RECO01-C-CER

**Installation scheme:**

